

Unisex Restroom

Signage	Id	Name	Status
	216.8	Sign with ADA symbol	true
	703.2	Raised characters	true
	703.3	Braille	true
	703.4.2	Located at latch side of door	true

Restroom Entrance	Id	Name	Status
	404.2.3	Door opening width: 32" min. when open 90 degree	true
	404.2.4	18" on pull side of door plus 60 degree clear	true
	404.2.7-a	Accessible handles operated by closed fist	true
	404.2.7-b	Handle height 34"-48"	true
	404.2.5, 303.2-3	Threshold 1/4" H max. or 1/4"+1/4" beveled	false
404.2.6	Vestibule: 48" min. plus width of doors	NA	

Inside Restroom	Id	Name	Status
	603.2.1, 304.3	Clear floor space: 60" diameter circle	false
	604.2	Toilet centerline from wall: 16"-18"	true
	604.3.1	Toilet clear floor space: 60" from side wall and 56" from rear wall	true
	604.4	Height of toilet seat: 17"-19"	true
	604.6a	Height of flush control: 15"-48"	true
	604.6b	Flush control located on open side of toilet	true
	604.5.1	Side wall grab bar: 42" L, 12" max. from wall	true
	609.4a	Side wall grab bar: 33"-36" H to top	true
	604.5.2	Rear wall grab bar: 36" L, 12" & 24" to toilet	true
	609.4b	Rear wall grab bar: 33"-36" H to top	true
	604.7a	TP dispenser: 7"-9" from front of toilet to ▯	true
	604.7b	Height of TP dispenser: 15"-48"	true
	604.7c	TP dispenser not located behind grab bar	false
	606.2	Sink clear floor space: 30" W x 48" D	true
606.3	Height of sink rim: 34" max.	true	

Inside Restroom	Id	Name	Status
	306.6.6	Knee clearance: 27" H min. x 8" D min.	true
	606.5	Pipe protection below sink	false
	606.4	Faucet handles: operable by closed fist	false
	603.3a	Bottom of mirror: 40" H max. if over sink	false
	603.3b	Bottom of mirror: 35" H max. if not over sink	NA
	308.2.2	Soap dispenser: 44" H max. if above sink	
	308.2	Soap dispenser: 48" H max. not above sink	false
	308.2.2, 308.2a	Paper towel dispenser: (same as soap)	false
	308.2.2, 308.2b	Electric hand dryer: (same as soap)	NA

Toilet Compartments (Stalls)	Id	Name	Status
	604.8.1.2a	Door opening width: 32" min. when open 90°	NA
	604.8.1.2b	18" on pull side of door	NA
	604.8.1.2c	Is stall door self-closing	NA
	309.4	Door lock: operable by closed fist	NA
	404.2.7c	Height of door lock: 34"-48"	NA
	604.8.1.1a	Stall width: 60" min.	NA
	604.8.1.1b	Stall depth: 56" min. wall hung toilet	
	604.8.1.1c	Stall depth: 59" min. floor mounted toilet	NA
	604.8.1.1d	Stall has door swing if door swings in	NA
	604.6c	Height of flush control: 15"-48"	NA